

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

SGWASA HAS LEVELS OF TOTAL TRIHALOMETHANES (TTHMs) ABOVE DRINKING WATER STANDARDS

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results for water samples collected during the time period ending September 30, 2017 show that the contaminant concentration from one or more sampling locations exceeds the standard or maximum contaminant level (MCL) for TOTAL TRIHALOMETHANES (TTHMs). The standard for TOTAL TRIHALOMETHANES is 0.080 milligrams per liter (mg/L). Over the referenced compliance period, the sample location with the highest average level of TOTAL TRIHALOMETHANES had a concentration of 0.090 mg/l.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. *However, some people who drink the water containing Total Trihalomethanes (TTHMs) in excess of the MCL over many years may have an increased risk of getting cancer.*

What happened? What is being done? When will the problem be corrected?

Test results for SGWASA's TOTAL TRIHALOMETHANES (TTHMs) samples taken on August 23, 2017 had a quarterly concentration of 0.077 mg/L at this location. The latest test results received for the sample taken on August 23, 2017 show the running annual average at this location to be 0.090 mg/L. The running annual average MCL is 0.080 mg/L, however the latest quarterly test results indicates that the water at this location is 0.077 mg/L, which meets the standard. An investigation as to the cause of the elevated (TTHM) level is ongoing and will continue until system compliance is achieved.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person Fred Dancy	System Name SGWASA	System Address (Street) 415 Central Ave. Suite B
Phone Number 919-575-3118	System PWSID# 02-39-107	System Address (City, State, Zip) Butner, N.C. 27509


Violation Awareness Date: October 27, 2017

Date Notice Distributed: November 20, 2017 Method of Distribution: Mailing

Public Notification Certification:

The public water system named above hereby affirms that public notification has been provided to its consumers in accordance with all delivery, content, format, and deadline requirements specified in 15A NCAC 18C.1523.

Owner/Operator:



(Signature)

Lindsay L. Mize
(Print Name)

November 2, 2017
(Date)

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

WILTON WATER & SEWER HAS LEVELS OF TOTAL TRIHALOMETHANES (TTHMs) ABOVE DRINKING WATER STANDARDS

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results for water samples collected during the time period ending June 30, 2017 show that the contaminant concentration from one or more sampling locations exceeds the standard or maximum contaminant level (MCL) for TOTAL TRIHALOMETHANES (TTHMs). The standard for TOTAL TRIHALOMETHANES is 0.080 milligrams per liter (mg/L). Over the referenced compliance period, the sample location with the highest average level of TOTAL TRIHALOMETHANES had a concentration of 0.086 mg/l.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. *However, some people who drink the water containing Total Trihalomethanes (TTHMs) in excess of the MCL over many years may have an increased risk of getting cancer.*

What happened? What is being done? When will the problem be corrected?

Test results for SGWASA's TOTAL TRIHALOMETHANES (TTHMs) sample for the sample taken on May 24, 2017 show the quarterly concentration at this location to be 0.086 mg/L. An investigation as to the cause of the elevated (TTHMs) level is ongoing and will continue until system compliance is achieved.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person	System Name	System Address (Street)
Fred Dancy	WILTON	415 Central Ave. Suite B
Phone Number	System PWSID#	System Address (City, State, Zip)
919-575-3118	40-39-004	Butner, N.C. 27509


Violation Awareness Date: July 20, 2017

Date Notice Distributed: August 19, 2017 Method of Distribution: Mailing

Public Notification Certification:

The public water system named above hereby affirms that public notification has been provided to its consumers in accordance with all delivery, content, format, and deadline requirements specified in 15A NCAC 18C .1523.

Owner/Operator:



(Signature)

Lindsay L. Mize
(Print Name)

August 15, 2017
(Date)